

H20 GL Series

The Utica Heating GL Series of Single Coil Glass Lined Indirect Water Heaters is an affordable water storage heating solution.

FEATURES

- Easy to Install
- Low Pressure Drop
- Magnesium Anode Rod Corrosion Protection
- Enameled Coated Steel Tank and Coil
- Minimal Standby Losses
- Flexible Scratch Resistant Jacket
- Aquastat Sensor Well
- Temperature Pressure Relief Valve
- Residential Limited Warranty: Tank, 7-Years; Parts, 2-Years
- Commercial Limited Warranty: Tank, 5-Years; Parts, 2-Years



H2O Glass Lined Indirect Water Heater

Item Number	Storage Volume	Coil Heating Surface	Dimensions (Inches)		Piping Connections N.P.T.		Approx. Wgt.
	Gallons	Square Feet	Height	Diameter	Domestic Water In/Out	Boiler Water In/Out	(lbs.)
H2OIG30UH	31	6.35	33	24	1	1	119
H2OIG40UH	42	14	45	24	1	1	180
H2OIG50UH	53	14	51	24	1	1	200
H2OIG80UH	79	20.7	48	30	1	1	243
H2OIG105UH	106	26	62	30	1	1	393

	Max. First Hour Rating	Continuous Rating	Boiler Output Needed	Boiler Water Flow Through the Coil	Pressure Drop Through the Coil	
Item Number	Gal./Hr. @ Gal./Hr. @		MDU	(Cal/Min)	/F4 \M/s4s*)	
	115° F	115° F	MBH	(Gal./Min.)	(Ft. Water)	
H2OIG30UH	116	93	75	14.0	7.5	
nzoiosiun	155	124	100	14.0		
H2OIG40UH	198	162	105	14.0	10.7	
H201G400H	256	220	120	14.0		
H2OIG50UH	212	169	110	14.0	10.7	
H2OlG300H	310	268	140	14.0		
H2OIG80UH	228	164	110	14.0	15.9	
H2OlGouun	346	281	180	14.0		
H2OIG105UH	270	175	115	14.0	19.7	
112010103011	440	345	220	14.0	13.7	

Note: All ratings are based on 180° F boiler water supply temperature. Domestic hot water 70° F rise, 45° F water inlet temperature. Specifications subject to change without notice.

Standard Equipment

Smooth enameled coil, magnesium anode rod and temperature pressure relief valve, Honeywell Aquastat. Water tank temperature gauge.





Honeywell Aquastat L4080B1352 (field installed)



ECR International, Inc. 2201 Dwyer Avenue, Utica, NY 13501 Tel. 800 253 7900 www.ecrinternational.com

All specifications subject to change without notice. ©2019 ECR International, Inc. PN 240012395 Rev. B [02/7/19]