



MULTIPLE BOILER CONTROL

MBC AMB4BUB

STAGING CONTROL

Ideal for multiple boiler system applications

The MBC Boiler Control operates up to four boilers to provide outdoor reset operation, domestic hot water and setpoint operation with priority.

CONTROL FEATURES

- Operation of up to Four Boilers
- LCD Display
- Push Buttons for Navigating Settings
- Warm Weather Shutdown (WWSD)
- Set Back Scheduling
- Boiler Stage Delay
- Boiler Rotation
- Combustion or Alarm Control Relay
- Flow or Combustion Air Proof Delay
- Energy Management System Compatible (0-10 or 2-10 Vdc)
- Sensors Included:(1) Outdoor Sensor(2) Water Temperature Sensors



Shown with UCS 240

PRODUCT SPECIFICATIONS



The Utica Boilers Multiple Boiler Control (MBC) operates up to four boilers and resets the heating system water temperature based on outdoor air temperatures. Utica boilers are piped in primary/secondary arrangement and the MBC control automatically selects how many boilers are needed to maintain the required heating load. Selecting multiple boilers maximizes your energy savings and provides backup heating capabilities.

- Up to 4 On/Off Boilers
- Up to 2 On/Off Boilers & 2 Pumps
- Up to 2 Lo/Hi Boilers

CONTROL OUTPUTS	
Boiler 1-4 Output Relay Rating	230 Vac, 5 A, 1/3 hp
DHW or Primary Pump Relay	230 Vac, 5 A, 1/3 hp
Primary Pump Relay	230 Vac, 5 A, 1/3 hp

Pri Me Do not apply 1 2 3 4 1 2 3 4 1 2 3 4 1 2 3 4 1 2 3 4 1 2 3 4 1 2 3 4 1 3 4 1 4 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 1 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 5 1 5 1 5 5 1 5 5 1 5	DHW / Setpoint Demand Proof Dem	US Deminds 20 to 280 V (so 2 V V S) Signal wiring must be rated at latest 300 V. 15 16 17 13 19 20 21, 22, 23, 24, 25, 6 10 10 10 10 10 10 10 10 10 10 10 10 10
Boiler Bus Input Outdoor Sensor Included OR 0-10 or 2-10 V (dc) from EMS Input Universal Sensor Included Input Universal Sensor Included	Output Up to 2 Boiler Pumps OR Output Up to 4 On/Off Boilers OR Alert	Input Demand Signal

CONTROL INPUTS		
Outdoor Sensor	NTC 10 k, @ 77°F (25°C)	
Boiler Supply Sensor	NTC 10 k, @ 77°F (25°C)	
Boiler Return Sensor	NTC 10 k, @ 77°F (25°C)	
Boiler Heating Demand Input Signal	20 to 260 Vac	
DHW or Setpoint Demand Input Signal	20 to 260 Vac	
Flow Proof or Combustion Air Demand Input	20 to 260 Vac	

ELECTRICAL SPECIFICATIONS		
Ambient conditions	Indoor use only. 32-104°F (0 to 40°C)	
Power Supply	115 Vac, +/- 10%, 60 Hz, 1 ph, 1150 VA Max	
Boiler control and Pump Relay (Volt free)	230 Vac 5 A 1/3 hp	
Demands (Input)	20-260 Vac	
Sensors	NTC Thermistor 10 k @ 77°F (25°C), β	
Combustion Air/Alarm relay output (Volt free)	230 Vac 5 A 1/3 hp	







